




liftinstituut  
SINCE 1933

# Energy Efficiency Certificate

Issued by Liftinstituut B.V.

Certificate number	NL24EPCL DB132306
Object number.	Not applicable
Address	Blomsterängsvägen 3 802 91 Gävle
User category	1
No. of days in use per year	260
Product description	Low speed cabin lift
Nominal load	630 kg
Nominal speed	0,15 m/s
Manufacturer, type, serial no.	Cibes C90 DB132306
Name and address installer	Cibes Utmarksvägen 13 802 91 Gävle
Name and address owner certificate	Cibes Utmarksvägen 13 802 91 Gävle
Certificate issued on the basis of the following requirements	EN-ISO 25745-2:2015
Performance level for running	6
Performance level idle	1
Performance level standby 5 min	1
Performance level standby 30 min	1
Date of examination	23-05-2024
Annexes to this certificate	Report of Energy Efficiency measurement NL24EPCL DB132306

Conclusion



The energy label shown is based on the energy efficiency measurement for the above mentioned lift.  
NOTE: The nominal speed of the installation is 0,15 m/s. According to ISO 25745-2 the performance levels and energy class can be taken as a reference.

Issued in Amsterdam  
Date of issue

24-05-2024

Certification decision by

  
W.G. Kasteleijn  
Product Manager Certification